

# **BRANZ Technical Opinion**

## **Summary**

**This is to certify that the specimen described below has been examined by BRANZ Ltd on behalf of**

Alsynite NZ Ltd  
7 De Leeuw Place  
Te Rapa  
Hamilton 3200  
New Zealand

**Test standard:** ISO 9705:1993

**Specimen name:**

- Laserlite 2000+
- Laserlite 3000
- Eurolite
- Eurolite 3
- Sunline
- Custom Glaze
- Alsynite Industrial Polycarbonate
- Laserlite Twinwall Polycarbonate profiled section, in 6 mm thickness
- Laserlite Twinwall Polycarbonate flat section, in 6 mm, 8 mm and 10 mm thicknesses.

**Specimen description:** Polycarbonate FR in various profiles, colours and thicknesses

**Orientation:** From the underside as tested

**A full description of the performance assessment is given in BRANZ Technical Opinion:**

FAR 4580-TO [2016] issued 21 June 2016

**Regulatory authorities are advised to examine reports before approving any product.**

**The conclusion of the Technical Opinion provides the following Building Code Classifications:**

<b>Building Code Document</b>	<b>Group Number Classification</b>
NZBC Verification Method C/VM2 Appendix A	1-S

**Issue Date:**  
21 June 2016

**Expiry Date:**  
21 June 2021